

# Data base OMIB (ULg, L. Wehenkel)

1650MVA


H=5.6s

Xt=87%

400kv system  
V-INFINI : 1.05 (st.dev 0.05 p.u.)

P-UNIT : 700 ... 1300MW

Q-UNIT: -665 ... 990Mvar



X-INFINI=60ohm (st.dev. 6ohm)

PI-LOAD= 100MW (st.dev. 10MW)

V-LOAD : V-INFINI + NOISE (st.dev. 0.01p.u.)

Pu : 1027.8 MW

Vl : 371.11 kv

Xinf : 56.571 ohm

CCT(SBS) : 137.2 ms

Qu : -89.8 Mvar


Pl : -99.74 MW

Vinf : 374.22 kv


**Ceci est un cas instable**

Path in the DT

DT2 : TOP-NODE, T19, T26, T28, T29, D22, (Conclusion is, SECURE, )




## MLP hidden layer activations (between -1 and 1)



MLP output activation 0.1756332

Model output 0.0



OP9008